

ELECTRICAL INSTALLATION CONDITION REPORT

Contractor's Reference Number

CRN/ N/A

Issued in accordance with *British Standard 7671 – Requirements for Electrical Installations* by an Approved Contractor or Conforming Body enrolled with NICEIC, Warwick House, Houghton Hall Park, Houghton Regis, Dunstable LU5 5ZX

Original (To the person ordering the work)

A. DETAILS OF THE CLIENT

Client: Rowney Green Village Hall	Address: Rowney Green Village Hall Rowney Green Lane Alvechurch	Postcode: B48 7QP
--------------------------------------	--	----------------------

B. PURPOSE OF THE REPORT

This report must be used only for reporting on the condition of an existing installation.

Purpose for which this report is required:	Scheduled Report
Date(s) on which inspection and testing were carried out:	01/03/2017 -- 15/03/2017

C. DETAILS OF THE INSTALLATION

Occupier: Rowney Green Village Hall	Address: Rowney Green Village Hall Rowney Green Lane Alvechurch	Postcode: B48 7QP
Estimated age of the electrical installation: 7 years	Description of premises: domestic, commercial, industrial, other (Please state) commercial	Evidence of alterations or additions no
Date of previous inspection: 01/03/2010	Electrical Installation Certificate No or previous Periodic Inspection or Condition Report No:	ICN2/0407797
Records of installation available: no	Records held by:	Unknown

D. EXTENT OF THE INSTALLATION AND LIMITATIONS ON THE INSPECTION AND TESTING

Extent of the electrical installation covered by this report:
Fixed wiring only

Agreed limitations including the reasons, if any, on the inspection and testing:
Agreed with: N/A

Operational limitations including the reasons (see page No.)
Unable to due insulation resistance test on lighting circuits due to discharge lighting
Unable to trace circuit DB2 10L3

The inspection and testing have been carried out in accordance with BS 7671, as amended. Cables concealed within trunking and conduits, or cables and conduits concealed under floors, in inaccessible roof spaces and generally within the fabric of the building or underground, have not been visually inspected unless specifically agreed between the client and inspector prior to the inspection.

E. SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety):
Very good

Summary of the condition of the installation continued on additional pages? No Yes Specify page No(s):

Overall assessment of the installation: **SATISFACTORY /** * An 'Unsatisfactory' assessment indicates that dangerous (CODE C1) and/or potentially dangerous (CODE C2) conditions have been identified, or that Further investigation without delay (FI) is required

This report should have been reviewed and confirmed by the registered Qualified Supervisor of the Approved Contractor responsible for issuing it. (See declaration on page 2)

NOTES FOR RECIPIENTS

THIS ELECTRICAL INSTALLATION CONDITION REPORT IS AN IMPORTANT AND VALUABLE DOCUMENT WHICH SHOULD BE RETAINED FOR FUTURE REFERENCE

The purpose of periodic inspection is to determine, so far as is reasonably practicable, whether an electrical installation is in a satisfactory condition for continued service (see Section E and G). This report provides an assessment of the condition of the electrical installation identified overleaf at the time it was inspected and tested, taking into account the stated extent of the installation and the limitations of the inspection and testing.

The report identifies any damage, deterioration, defects and/or conditions found by the inspector which may give rise to danger (see Section F), together with any items for which improvement is recommended.

If you were the person ordering this report, but not the user of the installation, you should pass this report, or a full copy of it including these notes, the schedules and additional pages (if any), immediately to the user.

This report should be retained in a safe place and shown to any person inspecting or undertaking further work on the electrical installation in the future. If you later vacate the property, this report will provide the new user with an assessment of the condition of the electrical installation at the time the periodic inspection was carried out.

Where the installation incorporates residual current devices (RCDs), there should be a notice at or near the distribution board stating that they should be tested quarterly. **FOR SAFETY REASONS, IT IS IMPORTANT THAT YOU CARRY OUT THE TEST REGULARLY.**

For safety reasons, the electrical installation should be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The recommended date by which the next inspection should be carried out is stated in Section I of this report. There should also be a notice at or near the main switchboard or consumer unit indicating when the next inspection of the installation is due. NICEIC* recommends that you engage the services of an Approved Contractor for the inspection.

This report has been issued in accordance with the national standard for the safety of electrical installations, British Standard 7671 (as amended) – *Requirements for Electrical Installations*.

Only an NICEIC Approved Contractor or Conforming Body is authorised to issue this NICEIC Electrical Installation Condition Report form.

You should have received the report marked 'Original' and the Approved Contractor should have retained the report marked 'Duplicate'.

The report consists of at least eight numbered pages. Additional numbered pages may have been provided to permit further relevant information relating to the installation to be recorded. For installations having more than one distribution board or more circuits than can be recorded on Pages 7 and 8, one or more additional *Schedules of Circuit Details and Schedules of Test Results* should form part of the report. The report is invalid if any of the pages identified in Section H are missing. The report has a printed seven-digit serial number, which is traceable to the Approved Contractor to which it was supplied by NICEIC.

This report form is intended to be issued only for the purpose of reporting on the condition of an existing electrical installation. The report should identify, so far as is reasonably practicable and having regard to the extent and limitations recorded in Section D, any damage, deterioration, defects, dangerous conditions and any non-compliances with the requirements of the national standard for the safety of electrical installations which may give rise to danger, together with any items for which improvement is recommended.

The report should not have been issued to certify that new electrical installation work complies with the requirements of the national safety standard. An 'Electrical Installation Certificate', a 'Domestic Electrical Installation Certificate' or a 'Minor Electrical Installation Works Certificate' (as appropriate) should be issued for the certification of new installation work.

This report should not have been issued for an electrical installation in a potentially explosive atmosphere (hazardous area) unless the Approved Contractor holds an appropriate extension to NICEIC enrolment for such work.

* NICEIC is operated by Certsure LLP, a partnership between the Electrical Contractors' Association and the charity, Electrical Safety First. NICEIC maintains and publishes registers of electrical contractors that it has assessed against particular scheme requirements (including the technical standard of electrical work).

For further information about electrical safety and how NICEIC can help you, visit www.niceic.com

continued on the reverse of page 3

GUIDANCE FOR RECIPIENTS ON THE CLASSIFICATION CODES

Only one Classification code should have been given for each recorded observation.

Classification code C1 (*Danger present*)

Where an observation has been given a Classification code C1, the safety of those using the installation is at risk and immediate remedial action is required.

The person responsible for the maintenance of the installation is advised to take action without delay to remedy the observed deficiency in the installation, or to take other appropriate action (such as switching off and isolating the affected part(s) of the installation) to remove the danger. The NICEIC Approved Contractor issuing this report will be able to provide further advice.

NICEIC makes available 'Electrical Danger Notification' forms to enable inspectors to record, and then to communicate to the person ordering the report, any dangerous condition discovered.

Classification code C2 (*Potentially dangerous*)

Classification code C2 indicates that, whilst those using the installation may not be at immediate risk, **urgent remedial action is required to remove potential danger**. The NICEIC Approved Contractor issuing this report will be able to provide further advice.

Classification code C3 (*Improvement recommended*)

Where an observation has been given a Classification code C3, the inspection and/or testing has revealed a non-compliance with the current safety standard which, whilst not presenting immediate or potential danger, would result in a significant safety improvement if remedied. Careful consideration should be given to the safety benefits of improving these aspects of the installation. The NICEIC Approved Contractor issuing this report will be able to provide further advice.

It is important to note that the recommendation given at Section I of this report (Next Inspection) for the maximum interval until the next inspection is conditional upon all items which have been given a Classification code C1 and code C2 being remedied immediately and as a matter of urgency, respectively.

It would not be reasonable for the inspector to indicate that the installation is in a satisfactory condition if any observation in this report has been given a code C1 or code C2 classification.

Code FI (*Further investigation required without delay*)

It should usually be possible for the inspector to attribute a Classification code to each observation without indicating a need for further investigation.

However, where 'FI' has been entered against an observation the inspector considers that further investigation of that observation is likely to reveal danger or potential danger that, due to the agreed extent or limitations of the inspection and/or testing, could not be fully identified at the time.

It would not be appropriate for the inspector to indicate that the installation is in a satisfactory condition if there is reasonable doubt as to whether danger or potential danger exists. Consequently, where the inspector has indicated 'Further investigation required without delay' (FI) the overall assessment of the installation (Section E) should be marked as 'Unsatisfactory'.

If the inspector has indicated that an observation requires further investigation without delay, the person ordering this report is advised to arrange for the NICEIC Approved Contractor issuing the report (or another skilled person or persons competent in such work) to undertake further examination of that aspect of the installation as a matter of urgency, to determine whether or not danger or potential danger exists.

Further information

Further information on the application of Classification codes, primarily aimed at inspectors but of possible interest to persons ordering condition reports, can be found in Electrical Safety First's Best Practice Guide entitled *Electrical installation condition reporting: Classification Codes for domestic and similar electrical installations*. The guide can be viewed or downloaded free of charge from www.electricalsafetyfirst.org.uk

NOTES FOR RECIPIENTS

(continued from the reverse of page 1)

Section D (*Extent and limitations*) should identify fully the extent of the installation covered by this report and any limitations on the inspection and testing. The inspector should have agreed these aspects with the person ordering the report and with other interested parties (licensing authority, insurance company, mortgage provider and the like) before the inspection was carried out. Some operational limitations may have been encountered during the inspection such as inability to gain access to parts of the installation or to an item of equipment. The inspector should have noted any such limitations in Section D. It should be noted that the greater the limitations applying to a report, the less its value from the safety aspect.

A declaration of the overall condition of the installation should have been given by the inspector in Section G of the report. The declaration must reflect the statement given in Section E, which summarises the observations and recommendations made in Section F. Where one or more observations have been made in Section F, the Classification code given to each by the inspector indicates the degree of urgency with which remedial action needs to be taken to restore the installation to a safe working condition.

Where the inspector has indicated an observation as code C1 (*danger present*) the safety of those using the installation is at risk, and it is recommended that a skilled person competent in electrical installation work undertakes the necessary remedial work immediately.

Where the inspector has indicated an observation as code C2 (*potentially dangerous*) the safety of those using the installation may be at risk, and it is recommended that a skilled person competent in electrical installation work undertakes the necessary remedial work as a matter of urgency.

Where the inspector has indicated that an item requires further investigation (FI), the investigation should be carried out without delay to determine whether danger or potential danger exists. For further guidance on the Classification codes, please see the reverse of page 2.

Where the installation can be supplied by more than one source, such as the public supply and a standby generator or microgenerator, the number of sources should have been recorded in Section K *Supply Characteristics and Earthing Arrangements* on page 3 of the report, and the *Schedule of Test Results* compiled accordingly.

Where inadequacies in the electricity distributor's or supplier's equipment have been observed (Section 1 of the inspection schedule), the person ordering the inspection should inform the distributor and/or supplier as appropriate.

Should the person ordering this report have reason to believe that it does not reasonably reflect the condition of the electrical installation reported on, that person should in the first instance raise the specific concerns in writing with the Approved Contractor. If the concerns remain unresolved, the person ordering this report may make a formal complaint to NICEIC, for which purpose a complaint form is available on request.

The complaints procedure offered by NICEIC is subject to certain terms and conditions, full details of which are available upon application. NICEIC does not investigate complaints relating to the operational performance of electrical installations (such as lighting levels), or to contractual or commercial issues (such as time or cost).

ELECTRICAL INSTALLATION CONDITION REPORT

H. SCHEDULES AND ADDITIONAL PAGES

Inspection Schedule: Page(s) No 4, 5, 6
 Additional pages, including additional source(s) data sheets: Page No(s)
 Schedule of Circuit Details for the Installation: Page No(s) 7,9,11,13,15,17
 Schedule of Test Results for the Installation: Page No(s) 8,10,12,14,16,18
 The pages identified are an essential part of this report. The report is valid only if accompanied by all the schedules and additional pages identified above.

I. NEXT INSPECTION

I/We recommend that this installation is further inspected and tested after an interval of not more than (Enter interval in terms of years, months or weeks, as appropriate)

provided that any items at F which have been attributed a Classification code C1 (danger present) are remedied immediately and that any items which have been attributed a code C2 (potentially dangerous) or FI (further investigation required without delay) are remedied or investigated respectively as a matter of urgency. Items which have been attributed a Classification code C3 should be improved as soon as practicable (see F).

J. DETAILS OF NICEIC APPROVED CONTRACTOR

Trading title:
 Address:
 Telephone number:
 Email address:
 Enrolment number: (Essential information)
 Branch number: (if applicable)
 Postcode:

K. SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

System type(s)	Number and type of live conductors			Nature of supply parameters			Characteristics of primary supply overcurrent protective device(s)						
	a.c.	d.c.		Nominal voltage(s), U ⁽¹⁾	Nominal frequency, f ⁽¹⁾	Prospective fault current, I _{pf} ^(2/3)	External earth fault loop impedance, Z _e ^(3/4)	Number of sources	BS(EN)	Type	Rated current	Short-circuit capacity	Confirmation of supply polarity
TN-S	N/A	<input checked="" type="checkbox"/>	<input type="checkbox"/>	400 V	50 Hz	16 kA	0.35 Ω	1	1361	2	100 A	33 kA	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/>
TN-CS	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	50 Hz									
TN-C	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>										
TT	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>										
IT	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										

L. PARTICULARS OF INSTALLATION AT THE ORIGIN

Means of earthing		Details of installation earth electrode (where applicable)	
Distributor's facility: <input checked="" type="checkbox"/>	Type: <input type="text" value="N/A"/> (eg rod(s), tape(s) etc)	Location: <input type="text" value="N/A"/>	
Installation earth electrode: <input type="text" value="N/A"/>	Electrode resistance, R _A : <input type="text" value="N/A"/> (Ω)	Method of measurement: <input type="text" value="N/A"/>	

Main Switch/Switch-Fuse/Circuit-Breaker/ RCD			Earthing and protective bonding conductors			
Type: BS(EN) <input type="text" value="BS EN 60947-3 Isolator"/>	Voltage rating: <input type="text" value="400"/> V	Rated current, I _n : <input type="text" value="100"/> A	Earthing conductor material: <input type="text" value="copper"/>	Main protective bonding conductor material: <input type="text" value="copper"/>	Bonding of extraneous-conductive-parts (✓)	
No of poles: <input type="text" value="3"/>	RCD operating current, I _{Δn} *: <input type="text" value="N/A"/> mA	Rated time delay*: <input type="text" value="N/A"/> ms	Conductor csa: <input type="text" value="16"/> mm ²	Conductor csa: <input type="text" value="10"/> mm ²	Water pipes installation: <input checked="" type="checkbox"/>	Lightning protection: <input type="text" value="N/A"/>
Primary supply conductors: material: <input type="text" value="copper"/>	RCD operating time (at I _{Δn})*: <input type="text" value="N/A"/> ms		Connection/continuity verified: <input checked="" type="checkbox"/> <input checked="" type="checkbox"/>	Connection/continuity verified: <input checked="" type="checkbox"/> <input checked="" type="checkbox"/>	Oil installation pipes: <input type="text" value="N/A"/>	Structural steel: <input type="text" value="N/A"/>
Primary supply conductors: csa: <input type="text" value="25"/> mm ²					Gas installation pipes: <input checked="" type="checkbox"/>	Other: <input type="text" value="N/A"/>

* (applicable only where an RCD is suitable and is used as a main circuit-breaker)

ELECTRICAL INSTALLATION CONDITION REPORT

Original (To the person ordering the work)

INSPECTION SCHEDULE FOR DISTRIBUTION BOARDS AND CIRCUITS

Item	Description	Outcome*	Location reference
1.0	Condition/adequacy of distributor's/supply intake equipment[†]		
1.1	Service cable	✓	
1.2	Service head	✓	
1.3	Distributor's earthing arrangement(s)	✓	
1.4	Meter tails – Distributor/ Consumer	✓	
1.5	Metering equipment	✓	
1.6	Means of main isolation (<i>where present</i>)	✓	
2.0	Presence of adequate arrangements for parallel or switched alternative sources		
2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply	N/A	
2.2	Adequate arrangements where a generating set operates in parallel with the public supply	N/A	
3.0	Automatic disconnection of supply		
3.1	Main earthing and bonding arrangements		
	• Presence and condition of distributor's earthing arrangement	✓	
	• Presence and condition of earth electrode arrangement	N/A	
	• Adequacy of earthing conductor size	✓	
	• Adequacy of earthing conductor connections	✓	
	• Accessibility of earthing conductor connections	✓	
	• Adequacy of main protective bonding conductor size(s)	✓	
	• Adequacy of main protective bonding conductor connections	✓	
	• Accessibility of main protective bonding connections	✓	
	• Accessibility and condition of other protective bonding connections	✓	
	• Provision of earthing/bonding labels at all appropriate locations	✓	
3.2	FELV		
	• Source providing at least simple separation	N/A	
	• Plugs, socket-outlets and the like not interchangeable with those of other systems within the premises	N/A	
3.3	Reduced low voltage		
	• Adequacy of source	✓	
	• Plugs, socket-outlets and the like not interchangeable with those of other systems within the premises	✓	
4.0	Other methods of protection (<i>where the methods of protection listed below are employed, details should be provided on separate sheets</i>)		
4.1	Double insulation	✓	
4.2	Reinforced insulation	✓	
4.3	Use of obstacles	N/A	
4.4	Placing out of reach	✓	
4.5	Non-conducting location	✓	
4.6	Earth-free local equipotential bonding	✓	
4.7	Electrical separation for more than one item of equipment	✓	
5.0	Distribution equipment		
5.1	Adequacy of working space/accessibility of equipment	✓	
5.2	Security of fixing	✓	
5.3	Condition of insulation of live parts	✓	
5.4	Adequacy/security of barriers	✓	
5.5	Condition of enclosure(s) in terms of IP rating	✓	
5.6	Condition of enclosure(s) in terms of fire rating	✓	
5.7	Enclosure not damaged/deteriorated so as to impair safety	✓	
5.8	Presence of main switch(es), linked where required	✓	
5.9	Operation of main switch(es) (<i>functional check</i>)	✓	
5.10	Correct identification of circuit protective devices	✓	
5.11	Adequacy of protective devices for prospective fault current	✓	
5.12	RCD(s) provided for fault protection – includes RCBOs	✓	
5.13	RCD(s) provided for additional protection – includes RCBOs	✓	

* All Outcome boxes must be completed.

✓ indicates **Acceptable condition**

'LIM' indicates a **Limitation**

'N/A' indicates **Not applicable**

Unacceptable condition state C1 or C2

Improvement recommended state C3

Further investigation required without delay state F1

(to determine whether danger or potential danger exists)

Outcome

Provide additional comment where appropriate on attached numbered sheets. C1, C2, C3 and F1 coded items to be recorded in Section F of the report.

[†] Where inadequacies in distributor's equipment are encountered, it is recommended that the person ordering the report informs the appropriate authority.

ELECTRICAL INSTALLATION CONDITION REPORT

INSPECTION SCHEDULE FOR DISTRIBUTION BOARDS AND CIRCUITS

Item	Description	Outcome*	Location reference
5.14	RCD(s) provided for protection against fire – includes RCBOs	✓	
5.15	Manual operation of circuit-breakers and RCDs to prove disconnection	✓	
5.16	Presence of RCD retest notice at or near equipment where required	✓	
5.17	Presence of diagrams, charts or schedules at or near equipment, where required	C3	DB3
5.18	Presence of non-standard (mixed) cable colour warning notice at or near equipment where required	N/A	
5.19	Presence of alternative/additional supply arrangement warning notice(s) at or near equipment where required	N/A	
5.20	Presence of replacement next inspection recommendation label	✓	
5.21	Presence of other required labelling (<i>specify</i>)	N/A	
5.22	Examination of protective device(s) and base(s); correct type and rating (<i>no signs of unacceptable thermal damage, arcing or overheating</i>)	✓	
5.23	Single-pole switching or protective devices in line conductors only	✓	
5.24	Protection against mechanical damage where cables enter equipment	✓	
5.25	Protection against electromagnetic effects where cables enter metallic enclosures	✓	
6.0	Distribution/final circuits		
6.1	Identification of conductors	✓	
6.2	Cables correctly supported throughout their length	✓	
6.3	Condition of insulation of live parts	✓	
6.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking	✓	
6.5	Suitability of containment systems for continued use (<i>including flexible conduit</i>)	✓	
6.6	Cables correctly terminated in enclosures (<i>indicate extent of sampling in Section D of report</i>)	✓	
6.7	Confirmation of indication that SPD(s) are functional	✓	
6.8	Confirmation that ALL conductor connections, including connections to busbars are correctly located in terminals and are tight and secure	✓	
6.9	Examination of cables for signs of unacceptable thermal and mechanical damage/deterioration	✓	
6.10	Adequacy of cables for current-carrying capacity with regard to the type and nature of installation	C3	BD1/6L1
6.11	Adequacy of protective devices; type and rated current for fault protection	✓	
6.12	Presence and adequacy of circuit protective conductors	✓	
6.13	Co-ordination between conductors and overload protective devices	✓	
6.14	Cable installation methods/practices appropriate to the type and nature of installation and external influences	✓	
6.15	Cables where exposed to direct sunlight, of a suitable type	✓	
6.16	Cables installed under floors, above ceilings, in walls / partitions, adequately protected against damage		
	• installed in prescribed zones (see Section D. Extent and limitations)	✓	
	• incorporating earthed armour or sheath, or installed within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see Section D. Extent and limitations)	✓	
6.17	Provision of additional protection by 30 mA RCD		
	• †for mobile equipment not exceeding a rating of 32 A for use outdoors	✓	
	• †for all socket-outlets of rating 20 A or less, unless exempt	✓	
	• †for cables installed in walls / partitions at a depth of less than 50 mm	✓	
	• †for cables installed in walls / partitions containing metal parts regardless of depth	✓	
6.18	Provision of fire barriers, sealing arrangements and protection against thermal effects	N/A	
6.19	Band II cables segregated/separated from Band I cables	✓	
6.20	Cables segregated/separated from non-electrical services	✓	
6.21	Termination of cables at enclosures (<i>identify numbers and locations of items inspected in Section D</i>)		
	• Connections under no undue strain	✓	
	• No basic insulation of a conductor visible outside an enclosure	✓	
	• Connections of live conductors adequately enclosed	✓	
	• Adequacy of connection at point of entry to enclosure (<i>gland, bush or similar</i>)	✓	
6.22	General condition of wiring systems	✓	
6.23	Temperature rating of cable insulation	✓	
6.24	Condition of accessories including socket-outlets, switches and joint boxes	✓	
6.25	Suitability of accessories for external influences	✓	
6.26	Single-pole switching or protective devices in line conductors only	✓	
6.27	Adequacy of connections, including cpcs, within accessories and to fixed and stationary equipment – identify /record numbers and locations of items inspected	✓	

† Note: Older installations designed prior to BS 7671:2008 may not have been provided with RCDs for additional protection

* All Outcome boxes must be completed.

✓ indicates Acceptable condition

'LIM' indicates a Limitation

'N/A' indicates Not applicable

Unacceptable condition state C1 or C2

Improvement recommended state C3

Further investigation required without delay state F1

(to determine whether danger or potential danger exists)

Outcome

Provide additional comment where appropriate on attached numbered sheets. C1, C2, C3 and F1 coded items to be recorded in Section F of the report.

Page 5 of

16

ELECTRICAL INSTALLATION CONDITION REPORT

INSPECTION SCHEDULE FOR DISTRIBUTION BOARDS AND CIRCUITS

Item	Description	Outcome*	Location reference
7.0	Isolation and switching		
7.1	Isolators		
	• presence and condition of appropriate devices	✓	
	• acceptable location (state if local or remote)		
	• capable of being secured in the OFF position	✓	
	• correct operation verified	✓	
	• clearly identified by position and/or durable marking(s)	✓	
	• Warning label posted in situations where live parts cannot be isolated by the operation of a single device	N/A	
7.2	Switching off for mechanical maintenance		
	• presence and condition of appropriate devices	✓	
	• acceptable location	✓	
	• capable of being secured in the OFF position	✓	
	• correct operation verified	✓	
	• clearly identified by position and/or durable marking(s)	✓	
7.3	Emergency switching/stopping		
	• presence and condition of appropriate devices	N/A	
	• readily accessible for operation where danger might occur	N/A	
	• correct operation verified	N/A	
	• clearly identified by position and/or durable marking(s)	N/A	
7.4	Functional switching		
	• presence and condition of appropriate devices	✓	
	• correct operation verified	✓	
8.0	Current-using equipment (<i>permanently connected</i>)		
8.1	Condition of equipment in terms of IP rating	✓	
8.2	Equipment does not constitute a fire hazard	✓	
8.3	Enclosure not damaged/deteriorated so as to impair safety	✓	
8.4	Suitability for the environment and external influences	✓	
8.5	Security of fixing	✓	
8.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire (<i>indicate extent of sampling in Section D of report</i>)	✓	
8.7	Recessed luminaires (e.g. downlighters)		
	• correct type of lamps fitted	N/A	
	• installed to minimise build-up of heat by use of "fire rated" fittings, insulation displacement box or similar	N/A	
	• no signs of overheating to surrounding building fabric	N/A	
	• no signs of overheating to conductors/terminations	N/A	
9.0	Location(s) containing a bath or shower		
9.1	Additional protection by RCD not exceeding 30 mA		
	• for low voltage circuits serving the location	N/A	
	• for low voltage circuits passing through Zone 1 and Zone 2 not serving the location	N/A	
9.2	Where used as a protective measure, requirements for SELV or PELV are met	N/A	
9.3	Shaver sockets comply with BS EN 61558-2-5 or BS 3535	N/A	
9.4	Presence of supplementary bonding conductors unless not required by BS 7671: 2008	N/A	
9.5	Low voltage (e.g. 230 volts) socket-outlets sited at least 3 m from zone 1	N/A	
9.6	Suitability of equipment for external influences for installed location in terms of IP rating	N/A	
9.7	Suitability of equipment for installation in a particular zone	N/A	
9.8	Suitability of current-using equipment for a particular position within the location	N/A	
10.0	Other special installations or locations		
	List special locations present, if any. List the results of particular inspections applied (a separate page is required for each location).	N/A	

* All Outcome boxes must be completed.

- ✓ indicates Acceptable condition
- 'LIM' indicates a Limitation
- 'N/A' indicates Not applicable

Unacceptable condition state C1 or C2

Improvement recommended state C3

Further investigation required without delay state FI (to determine whether danger or potential danger exists)

Outcome

Provide additional comment where appropriate on attached numbered sheets. C1, C2, C3 and FI coded items to be recorded in Section F of the report.

SCHEDULE OF CIRCUIT DETAILS FOR THE PRIMARY DISTRIBUTION BOARD

TO BE COMPLETED IN EVERY CASE	TO BE COMPLETED ONLY IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION*
Location of distribution board: Kitchen cupboard Distribution board designation: DB1	Supply to distribution board is from: _____ No of phases: _____ Nominal voltage: _____ V Overcurrent protective device for the distribution circuit: _____ Associated RCD (if any): BS (EN) _____ Type: _____ Rating: _____ A RCD No of poles: _____ I _{Δn} _____ mA BS (EN) _____

CIRCUIT DETAILS

Circuit number and line	Circuit designation	Type of wiring (see code below)	Reference method ↑	Number of points served	Circuit conductors: csa			Overcurrent protective devices				RCD	
					Live (mm ²)	cpc (mm ²)	Max. disconnection time permitted by BS 7671 (s)	BS (EN)			Operating current, I _{Δn} (mA)	Maximum Z _s permitted by BS 7671 (Ω)	
								Type	Rating (A)	Short-circuit capacity (kA)			
	Hall rad right hand side	A	100	1	2.5	1.5	0.4	61009	B	16	6	30	2.73
	Hall rad right hand side												
	Hall rad right hand side												
	Fire alarm	A	100	1	1.5	1.5	0.4	61009	B	16	6	30	2.73
	Hand dryer male WC	A	100	1	2.5	1.5	0.4	61009	B	16	6	30	2.73
	Hand dryer female WC	A	100	1	2.5	1.5	0.4	61009	B	16	6	30	2.73
	Hall rad left hand side	A	100	1	2.5	1.5	0.4	61009	B	16	6	30	2.73
	Hall rad left hand side	A	100	1	2.5	1.5	0.4	61009	B	16	6	30	2.73
	Hall rad left hand side	A	100	1	2.5	1.5	0.4	61009	B	16	6	30	2.73
	Rad male WC	A	100	1	2.5	1.5	0.4	61009	B	16	6	30	2.73
	Rad female WC	A	100	1	2.5	1.5	0.4	61009	B	16	6	30	2.73
	Water boiler kitchen	A	100	1	2.5	1.5	0.4	61009	B	16	6	30	2.73
	Heating boiler kitchen	A	100	1	2.5	1.5	0.4	61009	B	16	6	30	2.73
	Stage lts sso rear of hall	A	100	3	2.5	1.5	0.4	61009	B	16	6	30	2.73
	Dishwasher	A	100	1	4	2.5	0.4	61009	B	32	6	30	1.36
	Sockets Kitchen	A	100	10	2.5	1.5	0.4	61009	B	32	6	30	1.36
	Main hall & stage sockets	A	100	7	2.5	1.5	0.4	61009	B	32	6	30	1.36
	Skts lobby & rear of hall, roller shutter	A	100	4	2.5	1.5	0.4	61009	B	32	6		1.36
	Lights hall (pendants)	A	100	16	1.5	1	0.4	61009	B	10	6	30	4.37
	Lights kitchen & WC	A	100	16	1.5	1	0.4	61009	B	10	6	30	4.37
	Outside lights	A	100	9	2.5	1.5	0.4	61009	B	10	6	30	4.37
	Lights hall high rows	A	100	9	1.5	1	0.4	61009	B	10	6	30	4.37
	Overdoor heat control	A	100	1	2.5	1.5	0.4	60898	C	6	10	N/A	3.64
	Over door heat right of stage	A	100	1	2.5	1.5	0.4	61009	B	16	6	30	2.73

* In such cases, details of the distribution (sub-main) circuit(s), together with the test results for the circuit(s), must also be provided on continuation schedules.

↑ See Table 4A2 of Appendix 4 of BS 7671

CODES FOR TYPE OF WIRING								
A	B	C	D	E	F	G	H	0 (Other - please state)
Thermoplastic insulated/sheathed cables	Thermoplastic cables in metallic conduit	Thermoplastic cables in non-metallic conduit	Thermoplastic cables in metallic trunking	Thermoplastic cables in non-metallic trunking	Thermoplastic /SWA cables	Thermosetting /SWA cables	Mineral-insulated cables	

SCHEDULE OF TEST RESULTS FOR THE PRIMARY DISTRIBUTION BOARD

Original (To the person ordering the work)

<p>TO BE COMPLETED ONLY IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION</p> <p>Characteristics at this distribution board</p> <p>Confirmation of supply polarity</p> <p>* See note below</p> <p>Z_s * <input type="text"/> Ω Operating times of associated RCD (if any) At I_{Δn} <input type="text"/> ms</p> <p>I_{pf} * <input type="text"/> kA At 5I_{Δn} (if applicable) <input type="text"/> ms</p> <p>Phase sequence confirmed (where appropriate) <input type="checkbox"/> (✓)</p>	<p style="text-align: center;">Test instruments (serial numbers) used:</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;">Earth fault loop impedance</td> <td style="width: 30%;"><input type="text" value="1618200"/></td> <td style="width: 20%;">RCD</td> <td style="width: 20%;"><input type="text" value="1618200"/></td> </tr> <tr> <td>Insulation resistance</td> <td><input type="text" value="1618200"/></td> <td>Multi function</td> <td><input type="text" value="1618200"/></td> </tr> <tr> <td>Continuity</td> <td><input type="text" value="1618200"/></td> <td>Other</td> <td><input type="text"/></td> </tr> </table>	Earth fault loop impedance	<input type="text" value="1618200"/>	RCD	<input type="text" value="1618200"/>	Insulation resistance	<input type="text" value="1618200"/>	Multi function	<input type="text" value="1618200"/>	Continuity	<input type="text" value="1618200"/>	Other	<input type="text"/>
Earth fault loop impedance	<input type="text" value="1618200"/>	RCD	<input type="text" value="1618200"/>										
Insulation resistance	<input type="text" value="1618200"/>	Multi function	<input type="text" value="1618200"/>										
Continuity	<input type="text" value="1618200"/>	Other	<input type="text"/>										

TEST RESULTS														
Circuit number and line	Circuit impedances (Ω)					Insulation resistance <i>Record lower or lowest value</i>				Polarity (✓)	Maximum measured earth fault loop impedance, Z _s * (Ω)	RCD		Test button operation (✓)
	Ring final circuits only (measured end to end)			All circuits (At least one column to be completed)		Line/Line	Line/Neutral	Line/Earth	Neutral/Earth			Operating times		
	r ₁ (Line)	r _n (Neutral)	r ₂ (cpc)	(R ₁ + R ₂)	R ₂	(MΩ)	(MΩ)	(MΩ)	(MΩ)			at I _{Δn} (ms)	at 5I _{Δn} (if applicable) (ms)	
	N/A	N/A	N/A	.85	N/A	N/A	>500	>500	>500	✓	1.29	18	18	✓
	N/A	N/A	N/A	.19	N/A	N/A	>500	>500	>500	✓	.63	19	18	✓
	N/A	N/A	N/A	.68	N/A	N/A	>500	>500	>500	✓	1.12	21	18	✓
	N/A	N/A	N/A	.30	N/A	N/A	>500	>500	>500	✓	.74	21	13	✓
	N/A	N/A	N/A	.44	N/A	N/A	>500	>500	>500	✓	.88	18	18	✓
	N/A	N/A	N/A	1.12	N/A	N/A	>500	>500	>500	✓	1.56	18	18	✓
	N/A	N/A	N/A	.39	N/A	N/A	>500	>500	>500	✓	.83	18	18	✓
	N/A	N/A	N/A	.73	N/A	N/A	>500	>500	>500	✓	1.17	18	18	✓
	N/A	N/A	N/A	.27	N/A	N/A	>500	>500	>500	✓	.70	18	18	✓
	N/A	N/A	N/A	.13	N/A	N/A	>500	>500	>500	✓	.57	18	18	✓
	N/A	N/A	N/A	.34	N/A	N/A	>500	>500	>500	✓	.75	18	18	✓
	N/A	N/A	N/A	.39	N/A	N/A	>500	>500	>500	✓	.82	18	18	✓
	N/A	N/A	N/A	.27	N/A	N/A	>500	>500	>500	✓	.71	18	18	✓
	.37	.33	.62	.24	N/A	N/A	>500	>500	>500	✓	.56	20	13	✓
	.64	.64	.67	.32	N/A	N/A	>500	>500	>500	✓	.83	20	18	✓
	.31	.28	.50	.20	N/A	N/A	>500	>500	>500	✓	.72	32	23	✓
	N/A	N/A	N/A	1.52	N/A	N/A	LIM	LIM	LIM	✓	1.93	18	18	✓
	N/A	N/A	N/A	1.22	N/A	N/A	>500	>500	>500	✓	1.65	24	21	✓
	N/A	N/A	N/A	.82	N/A	N/A	LIM	LIM	LIM	✓	1.26	18	18	✓
	N/A	N/A	N/A	.98	N/A	N/A	LIM	LIM	LIM	✓	1.39	18	18	✓
	N/A	N/A	N/A		N/A	N/A	>500	>500	>500	✓				✓
	N/A	N/A	N/A		N/A	N/A	>500	>500	>500	✓				✓

* Note: Where the installation can be supplied by more than one source, such as a primary source (e.g. public supply) and a secondary source (e.g. standby generator), the higher or highest values must be recorded.

TESTED BY

Signature:	Position: Electrician	
Name: (CAPITALS) SEBASTIAN BENNET	Date of testing: 01/03/2017	

See previous page for Schedule of Circuit Details

SCHEDULE OF CIRCUIT DETAILS FOR THE INSTALLATION - CONTINUATION

Contractor's Reference Number

CRN/ N/A

TO BE COMPLETED IN EVERY CASE	TO BE COMPLETED ONLY IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION*	
Location of distribution board: Kitchen cupboard	Supply to distribution board is from: Origin of Supply	No of phases: 3 Nominal voltage: 400 V
Distribution board designation: DB1	Overcurrent protective device for the distribution circuit: Type: N/A Rating: 100 A	Associated RCD (if any): BS(EN) Not Applicable RCD No of poles: N/A $I_{\Delta n}$ N/A mA

CIRCUIT DETAILS														
Circuit number and line	Circuit designation	Type of wiring (see code below)	Reference method	Number of points served	Circuit conductors: csa			Overcurrent protective devices					RCD	
					Live (mm ²)	cpc (mm ²)	Max. disconnection time permitted by BS 7671 (s)	BS (EN)			Rating (A)	Short-circuit capacity (kA)	Operating current, $I_{\Delta n}$ (mA)	Maximum Z_s permitted by BS 7671 (Ω)
								Type	Rating	Short-circuit capacity				
	Stage left heater	A	100	1	2.5	1.5	0.4	61009	C	16	6	30	1.36	
	Overdoor heater main hall	A	100	1	2.5	1.5	0.4	61009	C	16	6	30	1.36	
	Overdoor heater lobby	A	100	1	2.5	1.5	0.4	61009	C	16	6	30	1.36	
	Cooker	A	100	1	6	2.5	0.4	61009	B	40	6	30	1.09	
	SPARE													
	SPARE													
	DB3	F	100	1	16	16	5	60898	C	63	10	N/A	0.34	
	DB2	F	100	1	16	16	5	60898	C	63	10	N/A	0.34	

* See Table 4A2 of Appendix 4 of BS 7671

CODES FOR TYPE OF WIRING									
A	B	C	D	E	F	G	H	0 (Other - please state)	
Thermoplastic insulated/sheathed cables	Thermoplastic cables in metallic conduit	Thermoplastic cables in non-metallic conduit	Thermoplastic cables in metallic trunking	Thermoplastic cables in non-metallic trunking	Thermoplastic /SWA cables	Thermosetting /SWA cables	Mineral-insulated cables		

* In such cases, details of the distribution (sub-main) circuit(s), together with the test results for the circuit(s), must also be provided on continuation schedules.

Original (To the person ordering the work)

SCHEDULE OF CIRCUIT DETAILS FOR THE INSTALLATION - CONTINUATION

Contractor's Reference Number

CRN/ N/A

TO BE COMPLETED IN EVERY CASE	TO BE COMPLETED ONLY IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION*	
Location of distribution board: Passage 1 rear of building	Supply to distribution board is from: _____	No of phases: _____ Nominal voltage: _____ V
Distribution board designation: DB2	Overcurrent protective device for the distribution circuit: Type: _____ Rating: _____ A	Associated RCD (if any): BS(EN) _____ RCD No of poles: _____ I _{Δn} _____ mA

CIRCUIT DETAILS

Circuit number and line	Circuit designation	Type of wiring (see code below)	Reference method	Number of points served	Circuit conductors: csa			Overcurrent protective devices				RCD	
					Live (mm ²)	cpc (mm ²)	Max. disconnection time permitted by BS 7671 (s)	BS (EN)			Operating current I _{Δn} (mA)	Maximum Z _s permitted by BS 7671 (Ω)	
								Type	Rating (A)	Short-circuit capacity (kA)			
	Overdoor heat control	A	100	2	2.5	1.5	0.4	60898	C	6	10	N/A	3.64
	Lights meeting rm & kit	A	100	15	1.5	1	0.4	61009	B	10	6	30	4.37
	Lights passage 1 & adj rms, Dis alarms	A	100	16	1.5	1	0.4	61009	B	10	6	30	4.37
	Lights passage 2 & snooker rm	A	100	12	1.5	1	0.4	61009	B	10	6	30	4.37
	Overdoor heater snooker rm	A	100	1	2.5	1.5	0.4	61009	B	16	6	30	2.73
	Overdoor heater meeting rm	A	100	1	2.5	1.5	0.4	61009	B	16	6	30	2.73
	Overdoor heat meeting rm	A	100	1	2.5	1.5	0.4	61009	B	16	6	30	2.73
	Passage 1 rad	A	100	1	2.5	1.5	0.4	61009	B	16	6	30	2.73
	Drama store rad	A	100	1	2.5	1.5	0.4	61009	B	16	6	30	2.73
	Dis WC rad	A	100	1	2.5	1.5	0.4	61009	B	16	6	30	2.73
	Passage 1 rad	A	100	1	2.5	1.5	0.4	61009	B	16	6	30	2.73
	WC rad	A	100	1	2.5	1.5	0.4	61009	B	16	6	30	2.73
	Dis WC hand dryer	A	100	1	2.5	1.5	0.4	61009	B	16	6	30	2.73
	Snooker rm rad	A	100	1	2.5	1.5	0.4	61009	B	16	6	30	2.73
	WC hand dryer	A	100	1	2.5	1.5	0.4	61009	B	16	6	30	2.73
	Passage 2 rad	A	100	1	2.5	1.5	0.4	61009	B	16	6	30	2.73
	Snooker rm rad	A	100	1	2.5	1.5	0.4	61009	B	16	6	30	2.73
	WC water heater	A	100	1	2.5	1.5	0.4	61009	B	16	6	30	2.73
	Meeting rm rad	A	100	1	2.5	1.5	0.4	61009	B	16	6	30	2.73
	Hall store rad	A	100	1	2.5	1.5	0.4	61009	B	16	6	30	2.73
	Far dis WC w/ heater	A	100	1	2.5	1.5	0.4	61009	B	16	6	30	2.73
	Meeting rm rad	A	100	1	2.5	1.5	0.4	61009	B	16	6	30	2.73
	Kitchen rad	A	100	1	2.5	1.5	0.4	61009	B	16	6	30	2.73
	Far dis WC rad	A	100	1	2.5	1.5	0.4	61009	B	16	6	30	2.73

↑ See Table 4A2 of Appendix 4 of BS 7671

CODES FOR TYPE OF WIRING									
A	B	C	D	E	F	G	H	O (Other - please state)	
Thermoplastic insulated/sheathed cables	Thermoplastic cables in metallic conduit	Thermoplastic cables in non-metallic conduit	Thermoplastic cables in metallic trunking	Thermoplastic cables in non-metallic trunking	Thermoplastic /SWA cables	Thermosetting /SWA cables	Mineral-insulated cables		

* In such cases, details of the distribution (sub-main) circuit(s), together with the test results for the circuit(s), must also be provided on continuation schedules.

SCHEDULE OF TEST RESULTS FOR THE INSTALLATION - CONTINUATION

Contractor's Reference Number

CRN/ N/A

TO BE COMPLETED ONLY IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Characteristics at this distribution board

Confirmation of supply polarity

* See note below

Z_s Ω Operating times of associated RCD (if any) At $I_{\Delta n}$ ms

I_{pf} kA At $5I_{\Delta n}$ (if applicable) ms

Phase sequence confirmed (where appropriate) (✓)

Test instruments (serial numbers) used:

Earth fault loop impedance	1618200	RCD	1618200
Insulation resistance	1618200	Multi-function	1618200
Continuity	1618200	Other	

TEST RESULTS															
Circuit number and line	Circuit impedances (Ω)					Insulation resistance † Record lower or lowest value				Polarity (✓)	Maximum measured earth fault loop impedance, Z_s^* (Ω)	RCD			
	Ring final circuits only (measured end to end)			All circuits (At least one column to be completed)		Line/Line †	Line/Neutral †	Line/Earth †	Neutral/Earth			operating times		Test button operation (✓)	
	r_1 (Line)	r_n (Neutral)	r_2 (cpc)	$(R_1 + R_2)$	R_2	(M Ω)	(M Ω)	(M Ω)	(M Ω)			at $I_{\Delta n}$ (ms)	at $5I_{\Delta n}$ (if applicable) (ms)		
	N/A	N/A	N/A	.17	N/A	N/A	>500	>500	>500	✓	.73	N/A	N/A	N/A	
	N/A	N/A	N/A	.45	N/A	N/A	LIM	LIM	LIM	✓	1.00	21	18	✓	
	N/A	N/A	N/A	.51	N/A	N/A	LIM	LIM	LIM	✓	1.07	55	25	✓	
	N/A	N/A	N/A	.98	N/A	N/A	LIM	LIM	LIM	✓	1.53	21	18	✓	
	N/A	N/A	N/A	.33	N/A	N/A	>500	>500	>500	✓	.88	18	18	✓	
	N/A	N/A	N/A	.30	N/A	N/A	>500	>500	>500	✓	.87	18	28	✓	
	N/A	N/A	N/A	.10	N/A	N/A	>500	>500	>500	✓	.66	18	18	✓	
	N/A	N/A	N/A	.10	N/A	N/A	>500	>500	>500	✓	.68	18	18	✓	
	N/A	N/A	N/A	.39	N/A	N/A	>500	>500	>500	✓	.96	18	28	✓	
	N/A	N/A	N/A	.29	N/A	N/A	>500	>500	>500	✓	.84	18	18	✓	
	N/A	N/A	N/A	.16	N/A	N/A	>500	>500	>500	✓	.71	28	18		
	N/A	N/A	N/A	LIM	N/A	N/A	LIM	LIM	LIM	✓	LIM	18	28	✓	
	N/A	N/A	N/A	.22	N/A	N/A	>500	>500	>500	✓	.77	21	13	✓	
	N/A	N/A	N/A	.44	N/A	N/A	>500	>500	>500	✓	.99	18	18	✓	
	N/A	N/A	N/A	.24	N/A	N/A	>500	>500	>500	✓	.81	21	13	✓	
	N/A	N/A	N/A	.26	N/A	N/A	>500	>500	>500	✓	.81	18	18	✓	
	N/A	N/A	N/A	.39	N/A	N/A	>500	>500	>500	✓	.94	18	18	✓	
	N/A	N/A	N/A	.21	N/A	N/A	>500	>500	>500	✓	.78	18	18	✓	
	N/A	N/A	N/A	.20	N/A	N/A	>500	>500	>500	✓	.75	18	28	✓	
	N/A	N/A	N/A	LIM	N/A	N/A	LIM	LIM	LIM	✓	LIM	28	18	✓	
	N/A	N/A	N/A	.52	N/A	N/A	>500	>500	>500	✓	1.09	18	18	✓	
	N/A	N/A	N/A	.31	N/A	N/A	>500	>500	>500	✓	.86	18	28	✓	
	N/A	N/A	N/A	.25	N/A	N/A	>500	>500	>500	✓	.80	18	28	✓	
	N/A	N/A	N/A	.40	N/A	N/A	>500	>500	>500	✓	.95	18	18	✓	

* Note: Where the installation can be supplied by more than one source, such as a primary source (e.g. public supply) and a secondary source (e.g. standby generator), the higher or highest values must be recorded.

TESTED BY

Signature:

Name: (CAPITALS) SEBASTIAN BENNET

Position: Electrician

Date of testing: 08/03/2017

See previous page for Circuit Details

SCHEDULE OF TEST RESULTS FOR THE INSTALLATION - CONTINUATION

Contractor's Reference Number
CRN/ N/A

TO BE COMPLETED ONLY IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Characteristics at this distribution board

Confirmation of supply polarity

* See note below

Z_s Ω Operating times of associated RCD (if any) At $I_{\Delta n}$ ms

I_{pf} kA At $5I_{\Delta n}$ (if applicable) ms

Phase sequence confirmed (where appropriate) (✓)

Test instruments (serial numbers) used:

Earth fault loop impedance	1618200	RCD	1618200
Insulation resistance	1618200	Multi-function	1618200
Continuity	1618200	Other	

TEST RESULTS														
Circuit number and line	Circuit impedances (Ω)					Insulation resistance † Record lower or lowest value				Polarity (✓)	Maximum measured earth fault loop impedance, Z_s^* (Ω)	RCD		
	Ring final circuits only (measured end to end)			All circuits (At least one column to be completed)		Line/Line †	Line/Neutral †	Line/Earth †	Neutral/Earth			operating times		Test button operation (✓)
	r_1 (Line)	r_n (Neutral)	r_2 (cpc)	$(R_1 + R_2)$	R_2	(M Ω)	(M Ω)	(M Ω)	(M Ω)			at $I_{\Delta n}$ (ms)	at $5I_{\Delta n}$ (if applicable) (ms)	
	N/A	N/A	N/A	.48	N/A	N/A	>500	>500	>500	✓	1.03	21	18	✓
	.58	.58	.99	.39	N/A	N/A	>500	>500	>500	✓	.98	20	18	✓
	.51	.49	.83	.33	N/A	N/A	>500	>500	>500	✓	.89	21	18	✓
	N/A	N/A	N/A	.25	N/A	N/A	>500	>500	>500	✓	.80	18	18	✓
	N/A	N/A	N/A	.45	N/A	N/A	LIM	LIM	LIM	✓	.95	66	40	✓
	N/A	N/A	N/A	LIM	N/A	N/A	LIM	LIM	LIM	✓	LIM	18	18	✓
	N/A	N/A	N/A	.45	N/A	N/A	>500	>500	>500	✓	1.00	18	28	✓

* Note: Where the installation can be supplied by more than one source, such as a primary source (e.g. public supply) and a secondary source (e.g. standby generator), the higher or highest values must be recorded.

TESTED BY

Signature: Position: Electrician

Name: (CAPITALS) SEBASTIAN BENNET Date of testing: 08/03/2017

SCHEDULE OF CIRCUIT DETAILS FOR THE INSTALLATION - CONTINUATION

Contractor's Reference Number

CRN/ N/A

TO BE COMPLETED IN EVERY CASE	TO BE COMPLETED ONLY IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION*	
Location of distribution board:	Supply to distribution board is from:	No of phases: Nominal voltage: V
Distribution board designation: DB3	Overcurrent protective device for the distribution circuit: Type: Rating: A	Associated RCD (if any): BS(EN) RCD No of poles: I _{Δn} mA

CIRCUIT DETAILS														
Circuit number and line	Circuit designation	Type of wiring (see code below)	Reference method	Number of points served	Circuit conductors: csa			Overcurrent protective devices					RCD	
					Live (mm ²)	cpc (mm ²)	Max. disconnection time permitted by BS 7671 (s)	BS (EN)			Rating (A)	Short-circuit capacity (kA)	Operating current I _{Δn} (mA)	Maximum Z _s permitted by BS 7671 (Ω)
								Type	Rating	Short-circuit capacity				
	Rack 1	D	100	1	6	6	0.4	61009	C	32	10	30	0.68	
	Rack 2	D	100	1	6	6	0.4	61009	C	32	10	30	0.68	
	SPARE													
	ND 1	A	100	LIM	2.5	2.5	0.4	61009	C	16	6	30	1.36	
	SPARE							ACB N-V					2.73	
	Rack 4	D	100	1	6	6	0.4	61009	C	32	10	30	0.68	
	ND2	A	100	1	2.5	2.5	0.4	61009	C	16	10	30	1.36	
	SPARE													
	Rack 5	D	100	1	6	6	0.4	61009	C	32	10	30	0.68	
	SPARE													
	Rack 3	D	100	1	6	6	0.4	61009	C	32	10	30	0.68	
	SPARE													
	ND3	A	100	LIM	2.5	2.5	0.4	61009	C	16	10	30	1.36	
	SPARE													
	SPARE													
	ND4	A	100	1	2.5	2.5	0.4	61009	C	16	10	30	1.36	
	SPARE													
	Control rm sockets	C	B	5	2.5	2.5	0.4	61009	B	20	6	30	2.18	

↑ See Table 4A2 of Appendix 4 of BS 7671

CODES FOR TYPE OF WIRING								
A	B	C	D	E	F	G	H	O (Other - please state)
Thermoplastic insulated/sheathed cables	Thermoplastic cables in metallic conduit	Thermoplastic cables in non-metallic conduit	Thermoplastic cables in metallic trunking	Thermoplastic cables in non-metallic trunking	Thermoplastic /SWA cables	Thermosetting /SWA cables	Mineral-insulated cables	

* In such cases, details of the distribution (sub-main) circuit(s), together with the test results for the circuit(s), must also be provided on continuation schedules.

Original (To the person ordering the work)

SCHEDULE OF TEST RESULTS FOR THE INSTALLATION - CONTINUATION

Contractor's Reference Number

CRN/ N/A

TO BE COMPLETED ONLY IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Characteristics at this distribution board

Confirmation of supply polarity

★ See note below

Z_s^* Ω Operating times of associated RCD (if any) At $I_{\Delta n}$ ms

I_{pf} kA At $5I_{\Delta n}$ (if applicable) ms

Phase sequence confirmed (where appropriate) (✓)

Test instruments (serial numbers) used:

Earth fault loop impedance	<input type="text"/>	RCD	<input type="text"/>
Insulation resistance	<input type="text"/>	Multi-function	<input type="text"/>
Continuity	<input type="text"/>	Other	<input type="text"/>

TEST RESULTS														
Circuit number and line	Circuit impedances (Ω)					Insulation resistance † Record lower or lowest value				Polarity (✓)	Maximum measured earth fault loop impedance, Z_s^* (Ω)	RCD		
	Ring final circuits only (measured end to end)			All circuits (At least one column to be completed)		Line/Line †	Line/Neutral †	Line/Earth †	Neutral/Earth			operating times		Test button operation (✓)
	r_1 (Line)	r_n (Neutral)	r_2 (cpc)	$(R_1 + R_2)$	R_2	(M Ω)	(M Ω)	(M Ω)	(M Ω)			at $I_{\Delta n}$ (ms)	at $5I_{\Delta n}$ (if applicable) (ms)	
N/A	N/A	N/A	N/A	.01	N/A	N/A	>500	>500	>500	✓	.50	18	18	✓
N/A	N/A	N/A	N/A	.01	N/A	N/A	>500	>500	>500	✓	.52	28	18	✓
N/A	N/A	N/A	N/A	LIM	N/A	N/A	LIM	LIM	LIM	✓	LIM	18	18	✓
N/A	N/A	N/A	N/A	.04	N/A	N/A	>500	>500	>500	✓	.67	18	18	✓
N/A	N/A	N/A	N/A	.37	N/A	N/A	LIM	LIM	LIM	✓	.86	18	18	✓
N/A	N/A	N/A	N/A	.04	N/A	N/A	>500	>500	>500	✓	.59	18	29	✓
N/A	N/A	N/A	N/A	.04	N/A	N/A	>500	>500	>500	✓	.62	18	18	✓
N/A	N/A	N/A	N/A	LIM	N/A	N/A	LIM	LIM	LIM	✓	LIM	18	18	✓
N/A	N/A	N/A	N/A	.41	N/A	N/A	LIM	LIM	LIM	✓	.90	18	18	✓
N/A	N/A	N/A	N/A	.10	N/A	N/A	>500	>500	>500	✓	.63	18	18	✓

* Note: Where the installation can be supplied by more than one source, such as a primary source (e.g. public supply) and a secondary source (e.g. standby generator), the higher or highest values must be recorded.

TESTED BY

Signature: <input type="text"/>	Position: <input type="text"/>
Name: (CAPITALS) <input type="text"/>	Date of testing: <input type="text"/>